



MID-SOUTH SIKH SABHA

1343 Panola Cove, Collierville, TN 38107

Tax ID #62-1775854



President: Mr. Surjit Singh Kamra (901) 755-0697

Secretary: Mr. Gurbinder Singh (901) 850-5255

**Wahe Guru Ji Ka Khalsa
Wahe Guru Ji Ki Fateh**

Minutes of MSSS GBC Meeting

Date of Meeting: March 10, 2005. (5:30PM)

Place of Meeting: The Gurdwara Sahib

Members Present: Sunpreet Singh, Charanjit Singh, Sammie Riar and Pritpal Bansal

The construction document presented by Braganza Associates And site plan presented by Civil Engineering Solutions were reviewed by the committee. The following points are for clarification and follow up.

1. All emergency exits on all 3 sides were Egresses. We had mentioned this and we wanted it egresses, but Claude mentioned that due to wind and safety factors it would be better to keep then Ingress's. Wanted to confirm that what you have is correct. We are happy to have it the way it is but wanted to confirm.
 2. The operable wall still shows that the storage is only on one side.
 3. Area 304 was meant to be Mechanical not Janitor. Also we would not want to have any doors open into corridors.
 4. 302 - Kitchen door. All Kitchen doors need to have view glass.
 5. Door 404 needs to be wider. Also we would like to make this a double door just the way we have for Commercial kitchens with a view glass. Swing both ways
 6. We would like to do a Center Floor drain in the Kitchen and would like to make the Floor surface concrete or something that can we washed with soap and washed.
 7. Would like to make sure we have drain and water Connections at both ends of the Kitchen. We can get into the details of that when we have a more detailed drawing of Electric Connects, water connections etc etc.
 8. Door 205 to the shower. We cannot have that go through the womens room. It must open to the other side where the entrance is.
 9. Door 206 to storage - same as above must open to the entrance. We understand that opening the Shower door would open to inside the shower and we can do the same with the storage door as well.
 10. The Washer dryer needs to be enclosed in a small area or Closet.
 11. Why do we need a roof hatch ladder? We are assuming that all HVAC units will be on the Ground and not the roof. We would prefer to have them on the ground.
 12. If we must have a Mop sink, I would rather have that in the 206 area with the storage.
- Meeting adjourned at 7:00 pm